Report Date: 9/14/2022 Report Time: 4:06 PM EDT

Region II Hotline Log Entry Information

**Data ID:** 2114905

**Date Of Report:** 3/15/2017 **NRC #:** 1173267 **State #: ERNS #:** 

Material Type: Oil Receiver: Lucarino

Material / Amount: TRANSMISSION FEEDER FLUID (300 GALLON(S));

**Location:** Street:

City: YONKERS County: WESTCHESTER

State: NY Latitude: Longitude:

Source of Pollution: CONSOLIDATED EDISON COMPANY OF NEW YORK

Water Body: N

State Or EPA Responded: RP Conducting leak detection operation

Initial EPA Action: Contacted RP Status: 2 - Closed

URL:

Associated Action Reports

DataID: 1028514

 Date: 3/15/2017
 Time: 10:13

 Duty Officer/Responder Name: Lucarino
 NRC Report #: 1173267
 Hotline Log DataID: 2114905

Action Information

Description: Con Ed experienced a loss of pressure in their #72 transmission line which runs between the Dunwoodie substation in Yonkers and the Mott substation in the Bronx. The transmission line runs adjacent to the Bronx River. Con Ed's leak

detection system indicated an initial loss of 300 gallons of dielectric fluid and a leak rate of 3.5 gallons per hour. Con Ed is currently conducting leak detection operations to determine the exact location of the leak. No sheen has been sighted in the

Bronx River as of yet. EPA R2 REOC will continue to monitor the situation.

Follup-Up:

Person Contacted

Name: Chris Blaich Organization: Con Ed Phone #: 212-580-8383

## **NRC Spill Report**

NATIONAL RESPONSE CENTER 1-800-424-8802

\*\*\*GOVERNMENT USE ONLY\*\*\*GOVERNMENT USE ONLY\*\*\*

Information released to a third party shall comply with any

applicable federal and/or state Freedom of Information and Privacy Laws

Incident Report # 1173267

INCIDENT DESCRIPTION

\*Report taken by: CIV ANTONAY GREER at 09:17 on 15-MAR-17

Incident Type: FIXED
Incident Cause: UNKNOWN

Affected Area:

Incident was discovered on 15-MAR-17 at 09:05 local incident time.

Affected Medium: UNKNOWN

REPORTING PARTY

Name: CHRIS BLAICH

Organization: CONSOLIDATED EDISON COMPANY OF NEW YORK

Address: 31ST ST AND 20TH AVE
ASTORIA, NY 11105

PRIMARY Phone: (212)5808383

Type of Organization: PUBLIC UTILITY

SUSPECTED RESPONSIBLE PARTY

Name: N/A

County: WESTCHESTER

Organization: CONSOLIDATED EDISON COMPANY OF NEW YORK

Address: 31ST ST AND 20TH AVE

ASTORIA, NY 11105

PRIMARY Phone: (212)5808383

Type of Organization: PUBLIC UTILITY

INCIDENT LOCATION

City: YONKERS State: NY

\* BETWEEN, 125 SMART AVE (YONKERS) TO 415 BUCKNER BLVD (BRONX)

RELEASED MATERIAL(S)

CHRIS Code: OTH Official Material Name: OTHER OIL

Also Known As: TRANSMISSION FEEDER FLUID

Qty Released: 300 GALLON(S) Qty in Water: 0 UNKNOWN AMOUNT

## DESCRIPTION OF INCIDENT

A SYSTEM INDICATION ALERTED THAT 300 GALLONS OF TRANSMISSION FEEDER FLUID DISCHARGED FROM AN UNKNOWN SOURCE; BETWEEN YONKERS AND THE BRONX.

\* FEEDER #72, 345KV FEEDER RUN.

INCIDENT DETAILS

Package: N/A Building ID:

Type of Fixed Object: POWER PLANT Power Generating Facility: YES

Generating Capacity:

Type of Fuel:

NPDES:

NPDES Compliance: UNKNOWN

IMPACT

Fire Involved: NO Fire Extinguished: UNKNOWN

INJURIES: NO Hospitalized: Empl/Crew: Passenger: FATALITIES: NO Empl/Crew: Passenger: Occupant:

EVACUATIONS: NO Who Evacuated: Radius/Area:

Damages: NO

Hours Direction of

<u>Closure Type</u> <u>Description of Closure</u> <u>Closed</u> <u>Closure</u>

Air: N

Road: N Major Arterv: N

Waterway: N

Track: N

Passengers Transferred: NO Environmental Impact: UNKNOWN

Media Interest: UNKNOWN Community Impact due to Material:

REMEDIAL ACTIONS

\* INVESTIGATION UNDERWAY

Release Secured: NO

Release Rate:

Estimated Release Duration:

WEATHER

Weather: CLEAR,  $\ddot{i}\dot{c}^{1/2}F$ 

ADDITIONAL AGENCIES NOTIFIED

Federal:

State/Local: NY-DEC & DEP State/Local On Scene: State Agency Number:

NOTIFICATIONS BY NRC

CENTERS FOR DISEASE CONTROL (GRASP)

15-MAR-17 09:29 (770)4887100

DHS DEFENSE THREAT REDUCTION AGENCY (CHEMICAL AND BIOLOGICAL TECHNOLOGIES DEPAR

15-MAR-17 09:29 (703)7673477

DHS INFRSTR SECURITY COMPLIANCE DIV (REGION 2)

15-MAR-17 09:29 (202)4655909

DOT CRISIS MANAGEMENT CENTER (MAIN OFFICE)

15-MAR-17 09:29 (202)3661863

U.S. EPA II (MAIN OFFICE)

15-MAR-17 09:30 (732)3214370 OSC LUCARINO

NATIONAL INFRASTRUCTURE COORD CTR (MAIN OFFICE)

15-MAR-17 09:29 (202)2829201

NJ OFC HMLND SECURITY & PREPAREDNES (COMMAND CENTER) 15-MAR-17 09:29 (609)9636817

NJ STATE POLICE (MARINE SERVICES BUREAU) 15-MAR-17 09:29 (609)9636900

NOAA RPTS FOR NY (MAIN OFFICE)

15-MAR-17 09:29 (206)5264911

NATIONAL RESPONSE CENTER HQ (AUTOMATIC REPORTS)
15-MAR-17 09:29 (202)2671136

NEW YORK CITY DEP (BUREAU OF WATER SUPPLY)
15-MAR-17 09:29 (845)3347188

NY STATE DEC SPILL HOTLINE (MAIN OFFICE)
15-MAR-17 09:29 (518)4577362

SECTOR NEW YORK (COMMAND CENTER)
15-MAR-17 09:32 (718)3544356 FYSA

CTDEP OIL & CHEM SPILL RESP DIV (MAIN OFFICE)
15-MAR-17 09:29 (860)4243338

USCG DISTRICT 1 (COMMAND CENTER)

(617)2238555

15-MAR-17 09:29

## ADDITIONAL INFORMATION

\*\*\* END INCIDENT REPORT # 1173267 \*\*\*
Report any problems by calling 1-800-424-8802
PLEASE VISIT OUR WEB SITE AT http://www.nrc.uscg.mil